

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1574:115 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004
Contact: *Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Model ADTQSC, -ADTQS1 and -ADTQS4 fire alarm control unit, *followed by -1 or -2 followed by -BR, -SP, -FR, -PG or no suffix. Local, local with shunt, auxiliary, remote station, releasing service or central station. Power limited. Non coded, coded, shunt, reverse polarity, DACT, manual, automatic waterflow, and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

*ADTQSC, ADTQS1, *ADTQS4	Control Units
7200001-01, 7200001-02, 7200004-01,	Enclosures
7200004-02, 7200005-01, or 7200005-02.	Enclosures
PS6	Power supply
ZB16-4	Class B zone card
AZ8-2	Class A zone card
DLD	Dialer (DACT) card
ZR8	Relay card
NT-A,	Class A, RS485 communication card
QS232,	232 port for download or printer functions
SL30	LED/Switch card with switch 1-30
SL30-1	LED/Switch card with switch 31-60
SLIC	Signature expansion loop card.

RATING: 120/220 VAC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Units can also generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature, the maximum retard/reset/restart shall not exceed 30 seconds.

XLF: 7165-1591:207

*Corrected 05-14-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 2, 2003

Listing Expires June 30, 2004

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager